



Clean-Agent Extinguishing System Permits

Clean agent extinguishing systems are issued from the BFD's standard installation application, with additional information required because of the nature and added control required for these systems. Speak with one of the BFD Fire Protection Engineers for additional guidance if needed. 617-343-2188.

Inergen

- General Fire Prevention Division Permit Application.
- Fire Alarm Permit, to review Inergen panel and devices.
- Sequence of Operations

FM200, CO2, Halons

- General Fire Prevention Division Permit Application.
- Fire Alarm Permit, to review agent panel and devices.
- Sequence of Operations
- Floor plans for egress review.
- Room Integrity test methodology.
- Mechanical Drawings and documentation for purge system.
- Emergency Breathing Apparatus provided to area occupants.